

## SAFE DRINKING WATER CERTIFICATE

Ref:- 1136

Date:- 10/06/23

It is certified that as per report water quality of drinking water of **Manas Inter National Public School, Vill- Dakshini, Jehanabad** has been found safe as per IS. 10500/2012

Water quality report attached.

Signature with seal:-

*Haider*  
10/06/2023

कार्यपालक अभियंता  
लोक स्वास्थ्य प्रमण्डल जहानाबाद

Name :- Ali Haider

Designation:- Executive Engineer

*Amit Kumar*  
10/06/2023

**CHEMIST**

P. H. E. D.,  
JEHANABAD.

**PUBLIC HEALTH ENGINEERING DEPARTMENT GOVT. OF BIHAR**

**WATER QUALITY OF DRINKING WATER SOURCES**

DISTRICT :- JEHANABAD

NAME OF P.H. DIVISION :- JEHANABAD

Date of Sampling :- 02-06-2023

Testing Date :- 05-06-2023

SP. No.	PARTICULARS OF THE SAMPLE						PARAMETERS EXAMINED (Value in mg/L, except pH, otherwise mentioned)														Bacteria	Type of Contamination found	Remarks (safe or Unsafe)
	District	Block	Gram-Panchayat	Village	Type of Source	Name & Location	Turbidity	pH	Conductivity	Total Hardness	Total Alkalinity	Calcium	Magnesium	Chloride	Sulphate	Iron	Nitrate	Fluoride	T.D.S	Arsenic			
1	Jehanabad	Kako	Derhsaiya	Dakshini	Ground Water	Manas Inter National Public School	0.5	7.30	1430	400	520	112.22	29.16	320	47.62	0.42	16.74	0.60	929	NT	-vc	Yes	
Min-Max. Permissible Limit (I.S. 10500/2012)							01-5 NTU	6.5 8.5	-	200 600	200 600	75 200	30 100	250 1000	200 400	1	45	1 1.5	500 2000	0.01			

Remarks: Submitted Sample of Water Confirm to IS 10500-2012 with respect to above test.

Signature of the Analyst.

*Amit Kumar*  
07/06/2023

Signature of the CHEMIST  
P.H Division Jehanabad.

**CHEMIST**  
P. H. E. D.,  
JEHANABAD

*Devika*  
07/06/2023

Executive Engineer  
P.H Division Jehanabad.

कार्यपालक अभियंता  
शेक र्वास्व प्रमण्डल जेहानाबाद